

MICRO ANALYTICAL LABORATORIES, INC.

PHASE CONTRAST MICROSCOPY


1122
C & W Environmental Consulting
2532 Santa Clara Avenue
PMB 390
Alameda, CA 94501

PROJECT:
COUNTY OF MONTEREY
SALINAS COURTHOUSE
NORTH WING
240 CHURCH STREET
SALINAS, CA

Micro Log In **86425**
Total Samples 7
Date Sampled 08/29/2006
Date Received 08/30/2006
Date Analyzed 08/30/2006

Sample ID	Field Data	Lab Data	Fibers / cc	Limits
Client: 82906-R1-1 Micro: 86425-01 OUTSIDE WORK AREA BASEMENT NORTH CORRIDOR AT MECHANICAL ROOM	Time 283 Rate 4 Liters 1132.0	Fibers 18 Fields 100 F/mm ² 22.3	0.008	LCL UCL 0.002 0.013 LOD LOQ 0.002 0.034 CV 0.35
Client: 82906-R1-2 Micro: 86425-02 OUTSIDE WORK AREA 1ST FLOOR LOBBY CORRIDOR AT WATER FOUNTAIN	Time 268 Rate 4 Liters 1072.0	Fibers 11.5 Fields 100 F/mm ² 14.0	0.005	LCL UCL 0.002 0.009 LOD LOQ 0.003 0.036 CV 0.35
Client: 82906-R1-3 Micro: 86425-03 KS OUTSIDE WORK AREA 1ST FLOOR COURT HALL AT JURY ROOM	Time 267 Rate 4 Liters 1068.0	Fibers 19 Fields 100 F/mm ² 23.6	0.009	LCL UCL 0.004 0.014 LOD LOQ 0.003 0.036 CV 0.30
Client: 82906-R1-4 Micro: 86425-04 OUTSIDE WORK AREA 3RD FLOOR MEZZANINE CORRIDOR AT WATER FOUNTAIN	Time 258 Rate 4 Liters 1032.0	Fibers 13 Fields 100 F/mm ² 15.9	0.006	LCL UCL 0.002 0.010 LOD LOQ 0.003 0.037 CV 0.35
Client: 82906-R1-5 Micro: 86425-05 OUTSIDE WORK AREA 3RD FLOOR COURT HALL AT JURY ROOM	Time 259 Rate 4 Liters 1036.0	Fibers 9 Fields 100 F/mm ² 10.8	0.004	LCL UCL 0.001 0.007 LOD LOQ 0.003 0.037 CV 0.35

Technical Supervisor: _____


Frank Raviola, M.S.

8/30/2006
Date Reported

Analyst: _____

KS

AIHA IHLAP Laboratory Accreditation / PAT ID No. 101768. Samples are analyzed using the NIOSH 7400 Method (NIOSH Manual of Analytical Methods, 4th Ed., Issue 2 of Rev. 3, 8/15/1994). The "A" Rules are used, unless otherwise noted. The limit of detection (LOD) is 7 fibers/mm³. Limits of quantification for optimal precision and accuracy are 100 (LOQ) and 1300 fibers/mm³. The 95% UCL and LCL (Upper and Lower Confidence Limits of the Two-sided 95% Confidence Interval) represent the highest and lowest expected concentrations (in fibers/cc) for a given fiber count, based on the reported concentration. Intralaboratory coefficients of variation (CV) for various fiber loadings are reported. Limits for compliance testing may be calculated by the client, using the CV and an appropriate regulatory standard, e.g. UCL = (Concentration + [1.645 x CV x Standard]). Concentrations are field blank-corrected. Time is in minutes, flow rate is in liters per minute, 8 Hour TWA: calculated time weighted average concentration (in fibers/cc) based on 8 hours. Note: due to method variability, 95% LCL and UCL for the TWA may vary significantly from reported TWA values. The 8 hour TWA may not be statistically accurate for actual total times less than 8 hours; zero concentration is assumed for remaining time if no information is given. Micro Analytical Laboratories, Inc. assumes no responsibility for clients' interpretation of any requested TWA data or calculations in this report. Unless otherwise indicated on this report, all required Quality Control samples have been determined to be in control prior to releasing these analytical results. This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unless otherwise stated in this report, all samples were received in acceptable condition for analysis. Micro Analytical Laboratories, Inc. shall not be responsible for clients' deviations from any prescribed sampling parameters. Air volumes are based on client data. The laboratory's verifiability of results is limited to fibers per mm³. N/A = not applicable.

MICRO ANALYTICAL LABORATORIES, INC.

PHASE CONTRAST MICROSCOPY

1122
C & W Environmental Consulting
2532 Santa Clara Avenue
PMB 390
Alameda, CA 94501

PROJECT:
COUNTY OF MONTEREY
SALINAS COURTHOUSE
NORTH WING
240 CHURCH STREET
SALINAS, CA

Micro Log In **86425**
Total Samples 7
Date Sampled 08/29/2006
Date Received 08/30/2006
Date Analyzed 08/30/2006

Sample ID	Field Data	Lab Data	Fibers / cc	Limits	
Client: BLANK Micro: 86425-06 SEALED BLANK	Time Rate Liters	Fibers 0 Fields 100 F/mm ² < 7.0		LCL	UCL
				LOD	LOQ
				CV	0.60
Client: BLANK Micro: 86425-07 FIELD BLANK	Time Rate Liters	Fibers 1 Fields 100 F/mm ² < 7.0		LCL	UCL
				LOD	LOQ
				CV	0.60

Technical Supervisor: _____



Frank Raviola, M.S.

8/30/2006
Date Reported

Analyst: _____

KS

AIHA IHLAP Laboratory Accreditation / PAT ID No. 101768. Samples are analyzed using the NIOSH 7400 Method (NIOSH Manual of Analytical Methods, 4th Ed., Issue 2 of Rev. 3, 8/15/1994). The "A" Rules are used, unless otherwise noted. The limit of detection (LOD) is 7 fibers/mm². Limits of quantification for optimal precision and accuracy are 100 (LOQ) and 1300 fibers/mm². The 95% UCL and LCL (Upper and Lower Confidence Limits of the Two-sided 95% Confidence Interval) represent the highest and lowest expected concentrations (in fibers/cc) for a given fiber count, based on the reported concentration. Intralaboratory coefficients of variation (CV) for various fiber loadings are reported. Limits for compliance testing may be calculated by the client, using the CV and an appropriate regulatory standard, e.g. UCL = (Concentration + [1.645 x CV x Standard]). Concentrations are field blank-corrected. Time is in minutes, flow rate is in liters per minute. 8 Hour TWA: calculated time weighted average concentration (in fibers/cc) based on 8 hours. Note: due to method variability, 95% LCL and UCL for the TWA may vary significantly from reported TWA values. The 8 hour TWA may not be statistically accurate for actual total times less than 8 hours; zero concentration is assumed for remaining time if no information is given. Micro Analytical Laboratories, Inc. assumes no responsibility for clients' interpretation of any requested TWA data or calculations in this report. Unless otherwise indicated on this report, all required Quality Control samples have been determined to be in control prior to releasing these analytical results. This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unless otherwise stated in this report, all samples were received in acceptable condition for analysis. Micro Analytical Laboratories, Inc. shall not be responsible for clients' deviations from any prescribed sampling parameters. Air volumes are based on client data. The laboratory's verifiability of results is limited to fibers per mm². N/A = not applicable.



C&W Environmental Consulting, Inc.

CHAIN OF CUSTODY

86425
PCM

Project

Sampling Date: 8/29/06

Client: County of Monterey - Salinas Courthouse - North Wing

Site Address: 240 Church St, Salinas

Page (s): 1 of 1

Turnaround Time: RUSH

ID	Analysis	Description	Start Time	Stop Time	Total Time	Average LPM	Total Liters	Pore Size
86425-01-1	PCM/TEM yank 2	DWA Basement north corridor @ mechanical room	4:00	8:43	283	4	1132	8µm
2		1st floor lobby corridor @ water fountain	4:00	8:20	268		1072	
3		↓ Court hall @ jury room	4:00	8:27	267		1068	
4		3rd floor - mezzanine corridor @ water fountain	4:00	8:48	258		1032	
5		↓ 3rd floor - court hall @ jury room	4:00	8:49	259		1036	
-	PCM	beard blank	:	:				
-	↓	field blank	:	:				

Additional Notes:

Thank you all!

Reimbursed by	Date & Time
<i>[Signature]</i>	8/30/06 2:00pm
Relinquished by	Date & Time
<i>[Signature]</i>	8/30/06 3:17

Received by	Date & Time
<i>[Signature]</i>	8/30/06 2:4
Received by	Date & Time
Kuo Saebel	8/30/06 3:30pm

Asbestos/Lead

2532 Santa Clara Avenue, PMB 390, Alameda, California 94501
 Phone (510) 769-7230 ♦ Fax (510) 769-7270
 www.cwenvironmental.net