

MICRO ANALYTICAL LABORATORIES, INC.

PHASE CONTRAST MICROSCOPY


1122
C & W Environmental Consulting
2532 Santa Clara Avenue
PMB 390
Alameda, CA 94501

PROJECT:
COUNTY OF MONTEREY
SUPERIOR COURTHOUSE
NORTH WING
240 CHURCH STREET
SALINAS, CA

Micro Log In **87146**
Total Samples 10
Date Sampled 09/18/2006
Date Received 09/19/2006
Date Analyzed 09/19/2006

Sample ID	Field Data	Lab Data	Fibers / cc	Limits	
Client: 91806-1 Micro: 87146-01 OUTSIDE WORK AREA BASEMENT NORTHWEST CORRIDOR	Time 591 Rate 4 Liters 2364.0	Fibers 9.5 Fields 100 F/mm ² 12.1	0.002	LCL 0.001 LOD 0.001 CV	UCL 0.003 LOQ 0.016 0.35
Client: 91806-2 Micro: 87146-02 OUTSIDE WORK AREA BASEMENT DECON AT IT ROOM CONTAINMENT	Time 547 Rate 4 Liters 2188.0	Fibers 28 Fields 100 F/mm ² 35.7	0.006	LCL 0.003 LOD 0.001 CV	UCL 0.010 LOQ 0.018 0.30
Client: 91806-3 Micro: 87146-03 OUTSIDE WORK AREA BASEMENT FILE ROOM SOUTH	Time 592 Rate 4 Liters 2368.0	Fibers 57 Fields 100 F/mm ² 72.6	0.012	LCL 0.005 LOD 0.001 CV	UCL 0.018 LOQ 0.016 0.28
Client: 91806-4 Micro: 87146-04 OUTSIDE WORK AREA BASEMENT FILE ROOM NORTH	Time 592 Rate 4 Liters 2368.0	Fibers 36 Fields 100 F/mm ² 45.9	0.007	LCL 0.003 LOD 0.001 CV	UCL 0.012 LOQ 0.016 0.30
Client: 91806-5 Micro: 87146-05 KS OUTSIDE WORK AREA BASEMENT PUBLIC ELEVATOR MACHINE ROOM	Time 588 Rate 4 Liters 2352.0	Fibers 5 Fields 100 F/mm ² < 7.0	< 0.001	LCL 0.000 LOD 0.001 CV	UCL 0.002 LOQ 0.016 0.60

Technical Supervisor: _____


Frank Raviola, M.S.

9/19/2006
Date Reported

Analyst: _____

KS

AIHA IHLAP LABORATORY Accreditation / PAT ID No. 101768. Samples are analyzed using the NIOSH 7400 Method (NIOSH Manual of Analytical Methods, 4th Ed., Issue 2 of Rev. 3, 8/15/1994). The "A" Rules are used, unless otherwise noted. The limit of detection (LOD) is 7 fibers/mm². Limits of quantification for optimal precision and accuracy are 100 (LOQ) and 1300 fibers/mm². The 95% UCL and LCL (Upper and Lower Confidence Limits of the Two sided 95% Confidence Interval) represent the highest and lowest expected concentrations (in fibers/cc) for a given fiber count, based on the reported concentration. Intralaboratory coefficients of variation (CV) for various fiber loadings are reported. Limits for compliance testing may be calculated by the client, using the CV and an appropriate regulatory standard, e.g. UCL = (Concentration + [1.645 x CV x Standard]). Concentrations are field blank-corrected. Time is in minutes, flow rate is in liters per minute. 8 Hour TWA: calculated time weighted average concentration (in fibers/cc) based on 8 hours. Note: due to method variability, 95% LCL and UCL for the TWA may vary significantly from reported TWA values. The 8 hour TWA may not be statistically accurate for actual total times less than 8 hours; zero concentration is assumed for remaining time if no information is given. Micro Analytical Laboratories, Inc. assumes no responsibility for clients' interpretation of any requested TWA data or calculations in this report. Unless otherwise indicated on this report, all required Quality Control samples have been determined to be in control prior to releasing these analytical results. This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unless otherwise stated in this report, all samples were received in acceptable condition for analysis. Micro Analytical Laboratories, Inc. shall not be responsible for clients' deviations from any prescribed sampling parameters. Air volumes are based on client data. The laboratory's verifiability of results is limited to fibers per mm². N/A = not applicable.

MICRO ANALYTICAL LABORATORIES, INC.

PHASE CONTRAST MICROSCOPY


1122
C & W Environmental Consulting
2532 Santa Clara Avenue
PMB 390
Alameda, CA 94501

PROJECT:
**COUNTY OF MONTEREY
SUPERIOR COURTHOUSE
NORTH WING
240 CHURCH STREET
SALINAS, CA**

Micro Log In **87146**
Total Samples 10
Date Sampled 09/18/2006
Date Received 09/19/2006
Date Analyzed 09/19/2006

Sample ID	Field Data	Lab Data	Fibers / cc	Limits	
Client: 91806-6 Micro: 87146-06 OUTSIDE WORK AREA BASEMENT IT ROOM	Time 594 Rate 4 Liters 2376.0	Fibers 18.5 Fields 100 F/mm ² 23.6	0.004	LCL 0.001 LOD 0.001 CV	UCL 0.006 LOQ 0.016 0.35
Client: 91806-7 Micro: 87146-07 OUTSIDE WORK AREA BASEMENT HOLDING CELLS	Time 596 Rate 4 Liters 2384.0	Fibers 15 Fields 100 F/mm ² 19.1	0.003	LCL 0.001 LOD 0.001 CV	UCL 0.005 LOQ 0.016 0.35
Client: 91806-8 Micro: 87146-08 OUTSIDE WORK AREA BASEMENT SECURE ELEVATOR MACHINE ROOM	Time 596 Rate 4 Liters 2384.0	Fibers 7 Fields 100 F/mm ² 8.9	0.001	LCL 0.000 LOD 0.001 CV	UCL 0.002 LOQ 0.016 0.35
Client: BLANK Micro: 87416-14 SEALED BLANK	Time Rate Liters	Fibers 0 Fields 100 F/mm ² < 7.0		LCL LOD CV	UCL LOQ 0.60
Client: BLANK Micro: 87146-10 FILED BLANK	Time Rate Liters	Fibers 0 Fields 100 F/mm ² < 7.0		LCL LOD CV	UCL LOQ 0.60

Technical Supervisor: _____



FR Frank Raviola, M.S.

9/19/2006
Date Reported

Analyst: _____

KS

AIHA IHLAP LABORATORY Accreditation / PAT ID No. 101768. Samples are analyzed using the NIOSH 7400 Method (NIOSH Manual of Analytical Methods, 4th Ed., Issue 2 of Rev. 3, 8/15/1994). The "A" Rules are used, unless otherwise noted. The limit of detection (LOD) is 7 fibers/mm². Limits of quantification for optimal precision and accuracy are 100 (LOQ) and 1300 fibers/mm². The 95% UCL and LCL (Upper and Lower Confidence Limits of the Two sided 95% Confidence Interval) represent the highest and lowest expected concentrations (in fibers/cc) for a given fiber count, based on the reported concentration. Intralaboratory coefficients of variation (CV) for various fiber loadings are reported. Limits for compliance testing may be calculated by the client, using the CV and an appropriate regulatory standard, e.g. UCL = (Concentration + [1.645 x CV x Standard]). Concentrations are field blank-corrected. Time is in minutes, flow rate is in liters per minute. 8 Hour TWA: calculated time weighted average concentration (in fibers/cc) based on 8 hours. Note: due to method variability, 95% LCL and UCL for the TWA may vary significantly from reported TWA values. The 8 hour TWA may not be statistically accurate for actual total times less than 8 hours; zero concentration is assumed for remaining time if no information is given. Micro Analytical Laboratories, Inc. assumes no responsibility for clients' interpretation of any requested TWA data or calculations in this report. Unless otherwise indicated on this report, all required Quality Control samples have been determined to be in control prior to releasing these analytical results. This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unless otherwise stated in this report, all samples were received in acceptable condition for analysis. Micro Analytical Laboratories, Inc. shall not be responsible for clients' deviations from any prescribed sampling parameters. Air volumes are based on client data. The laboratory's verifiability of results is limited to fibers per mm². N/A = not applicable.



C&W Environmental Consulting, Inc.

CHAIN OF CUSTODY

87146
PCW

Client: County of Monterey – Superior Courthouse North Wing
 Site Address: 240 Church Street, Salinas CA
 Project: _____
 Sampling Date: 9/18/06
 Page (s): 1 of 1
 Turnaround Time: RUSH

ID	Analysis	Description	Start Time	Stop Time	Total Time	Average LPM	Total Liters	Pore Size
91806 - 1	Perm/TEM gamma	Basement hatchwest corner	7:20	17:11	591	1	2364	0.8µm
2		Beam @ IT room entrance	8:05	17:12	547		2188	
3		File room south	7:18	17:10	592		2368	
4		File room north	7:17	17:09	592		2368	
5		Public copier machine room	7:15	17:03	588		2352	
6		IT room	7:14	17:08	594		2376	
7		holding cells	7:11	17:07	596		2384	
8		server copier machine room	7:10	17:06	596		2384	
-	PCW	steel base						
-		feed base						

Additional Notes:

Relinquished by: *[Signature]* Date & Time: 9/18/06 8:00pm

Received by: *[Signature]* Date & Time: 9/18/06 8:00pm

Relinquished by: *[Signature]* Date & Time: 9/18/06 8:00pm

Received by: *[Signature]* Date & Time: 9/19/06 4:00pm

Asbestos/Lead: _____
 2532 Santa Clara Avenue, PMB 390, Alameda, California 94501
 Phone (510) 769-7230 ♦ Fax (510) 769-7270
 www.cwenvironmental.net